

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 10, 1993 Apartment # 1945 Fourth St. Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg/Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
DJ	0	.1	0	.03								Negative
Cabinets	0	0	0	0								Negative
<u>Utility Closet</u>												
W	0	0	.1	.03								Negative
C	0	0	0	0								Negative
EPB	0	0	0	0								Negative
Door	.1	0	0	.03								Negative
<u>Pantry</u>												
W	0	.1	0	.03								Negative
C	0	.1	.2	.1								Negative
Shelf Bracket	0	.1	.1	.06								Negative
BB	0	0	0	0								Negative

All Varnished Wood Surfaces - 0

