

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2601 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
LR/DJ	0	0	0	0								Negative
LR/D Metal	.7	.6	.8	.7	.5	.5	.5	.50	.2			Negative
LR/W	0	0	0	0								Negative
LR/CW	0	0	0	0								Negative
K/W	0	0	0	0								Negative
K/D Metal	.7	.7	.6	.66	.5	.5	.5	.50	.16			Negative
K/CW #1	0	0	0	0								Negative
K/CW #2	0	0	0	0								Negative
HC	0	0	0	0								Negative
BR 1/W	0	.1	0	.03								Negative
BR 1/C	0	0	0	0								Negative
BR 2/W	.1	0	.1	.06								Negative
BR 2/C	0	0	0	0								Negative

RR/W 0 .1 0 .03

Negative