ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2603 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
LR/DJ	0	0	0	0								Negative
LR/D Metal	1.0	.8	.8	.86	.6	.6	.6	.60	.26			Negative
LR/W	0	0	0	0								Negative
LR/CL/W	0	0	0	0								Negative
LR/CL/S	0	0	0	0								Negative
K/W	0	0	0	0								Negative
K/D Metal	.5	1.0	.7	.73	.5	.5	.5	.50	.23			Negative
K/CW #1	0	0	0	0								Negative
K/CW #2	.2	0	.1	.1								Negative
HC Wall	0	.1	0	.03								Negative
RR	0	0	0	0								Negative
BR 1/W	0	.1	0	.03								Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2603 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
BR 1/C	0	0	0	0								Negative
BR 2/W	0	0	0	0								Negative
BR 2/C	0	0	0	0								Negative
Ceiling	0	0	0	0								Negative
Ext. Win. Cas.	0	0	0	0								Negative