ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2605 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Ext. Win. Cas.	0	0	0	0								Negative
LR/DJ	0	0	0	0								Negative
LR/D	.4	.5	.5	.46								Negative
LR/W	0	0	0	0								Negative
LR/CW	0	0	0	0								Negative
K/W	.1	0	0	.03								Negative
K/D Metal	.7	.6	.6	.63	.5	.5	.6	.53	.10			Negative
K/CW #1	0	0	0	0								Negative
K/CW #2	0	0	0	0								Negative
K/CS	0	0	0	0								Negative
HC/W	0	0	0	0								Negative
BR 1/W	0	0	0	0								Negative
BR 1/C	0	0	0	0								Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2605 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
BR 2/W	0	0	0	0								Negative
BR 2/C	0	0	0	0								Negative
Ceiling	0	0	0	0								Negative
RR/W	0	0	0	0								Negative
RR/CM	0	0	0	0								Negative