ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 18, 1993 Apartment # 2606 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

| Sample Number | Reading (mg/cm2) | | | | S.E.L. (mg/cm2) | | | | C.L.C. (mg/cm2) | Conformation Test | | Result Neg./Abate |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | 1 | 2 | 3 | Avg | 1 | 2 | 3 | Avg | | No. | Result | |
| Ext. Win. Cas. | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| LR/DJ | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| LR/D/Metal | .8 | .6 | .6 | .66 | .4 | .5 | .5 | .46 | .20 | | | Negative |
| LR/W | 0 | .1 | .1 | .06 | | | | | | | | Negative |
| LR/CW | 0 | 0 | .1 | .03 | | | | | | | | Negative |
| K/W | .1 | .1 | .1 | .1 | | | | | | | | Negative |
| K/D | .6 | .4 | .4 | .46 | | | | | | | | Negative |
| K/CW #1 | .1 | .1 | .1 | .1 | | | | | | | | Negative |
| K/CW #2 | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| HC/W | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| HC/Ceiling | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| RR/W | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| BR1/W | 0 | 0 | 0 | 0 | | | | | | | | Negative |

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 18, 1993 Apartment # 2606 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

| Sample Number | Reading (mg/cm2) | | | | S.E.L. (mg/cm2) | | | | C.L.C. (mg/cm2) | Conformation Test | | Result Neg./Abate |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | 1 | 2 | 3 | Avg | 1 | 2 | 3 | Avg | | No. | Result | |
| BR1/CW | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| BR2/W | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| BR2/CW | 0 | 0 | 0 | 0 | | | | | | | | Negative |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |
| | | | | | | | | | | | | |