ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2615 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
LR/DJ	0	0	0	0								Negative
LR/DC Metal	.5	.5	.5	.5	.5	.5	.5	.5	0			Negative
LR/W	0	0	0	0								Negative
LR/C	0	0	0	0								Negative
K/W	0	0	0	0								Negative
K/D Metal	.9	.9	.8	.86	.5	.6	.6	.56	.30			Negative
K/CW #1	0	0	0	0								Negative
K/CW #2	0	0	0	0								Negative
HC	0	0	0	0								Negative
RR/W	0	0	0	0								Negative
BR 1/W	0	0	0	0								Negative
BR 1/C	0	0	0	0								Negative
BR 2/W	0	0	0	0								Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 2615 Harbor Dr. Project: Area 7 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
BR 2/C	0	0	0	0								Negative
Ceiling	0	0	0	0								Negative