

ENVIRONMENTAL CONTROL TECHNOLOGIES

LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 422 Meigs Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm2)				S.E.L. (mg/cm2)				C.L.C. (mg/cm2)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
<u>Living Room</u>												
Front Door (M)	1.1	1.0	1.0	1.03	.7	.8	.7	.73	.3			Negative
DJ	10.0	10.0	10.0	10.0								Abate
IDC	.2	.3	.2	.23								Negative
Wall	0	0	0	0								Negative
Ceiling	10.0 8.4	10.0 7.8	10.0 7.8	10.0 8.0	Living Room ceiling readings taken at 6 different locations							Abate
Baseboard	.7	1.0	.7	.8	.3	.3	.4	.33	.47			Negative
W. Cas.	0	.1	0	.03								Negative
W. Sill	0	0	0	0								Negative
W. Apron	0	0	0	0								Negative
<u>Dining Room</u>												
Wall	.3	.3	.3	.3								Negative
Ceiling	.5	.4	.4	.43								Negative

Baseboard .1 0 0 .03

Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 422 Meigs Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Wall	.5	.4	.4	.43								Negative
Ceiling	.3	.3	.3	.3								Negative
Wall BD	.1	0	0	.03								Negative
W. Sill	0	.1	.1	.06								Negative
W. Apron	0	0	0	0								Negative
W. Cas.	0	.1	0	.03								Negative
<u>Ext. Door</u>												
Door	.5	.5	.5	.5	.1	.1	.1	.1	.4			Negative
IDC	.7	.4	.3	.46								Negative
DJ	10.0	10.0	10.0	10.0								Abate
<u>Basement</u>												
Door	.2	.1	.2	.16								Negative
Toward K/IDC	0	0	0	0								Negative

EDC 4.4 4.2 4.3 4.3

Abate

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 422 Meigs Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
DJ	5.9	5.7	5.8	5.8								Abate
Wall	.5	.4	.4	.43								Negative
Ceiling	0	.3	0	.1								Negative
Coat	8.1	8.0	8.0	8.03								Abate
St. Riser	7.9	8.1	8.0	8.0								Abate
Shelf	4.8	5.0	5.1	4.96								Abate
Shelf Bracket	5.6	5.5	5.5	5.53								Abate
<u>Exterior Door</u>												
Door (M)	.3	.4	.3	.33								Negative
IDC	6.7	6.6	6.5	6.6								Abate
DJ	3.5	3.3	3.4	3.4								Abate
Windows	10.0	10.0	10.0	10.0								Abate
Brick Wall	.9	.8	.9	.86	.7	.7	.7	.7	.16			Negative

Wood St. Walls .7 .7 .7 .7 .3 .4 .3 .33 .27 Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 9, 1993 Apartment # 422 Meigs Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
<u>Exterior</u>												
Post	10.0	10.0	10.0	10.0								Abate
Siding	10.0	10.0	10.0	10.0								Abate
White Rail	10.0	10.0	10.0	10.0								Abate
Metal Rail	1.0	1.0	.9	.96	.7	.7	.7	.70	.26			Negative
Header	10.0	10.0	10.0	10.0								Abate
Soffitt	10.0	10.0	10.0	10.0								Abate
Porch Ceiling	.4	.4	.4	.40								Negative
Fascia	10.0	10.0	10.0	10.0								Abate
Porch	0	0	0	0								Negative
Porch Kickboard	.1	.1	.1	.10								Negative
Basement Wind.	10.0	10.0	10.0	10.0								Abate

Aluminum on Windows

