





ENVIRONMENTAL CONTROL TECHNOLOGIES

LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 529 Pearl Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm <sup>2</sup> )				S.E.L. (mg/cm <sup>2</sup> )				C.L.C. (mg/cm <sup>2</sup> )	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Dining/W. Apron	10.0	10.0	10.0	10.0								Abate
<u>Walkin Closet</u>												
EDC	.2	.2	.3	.23								Negative
DJ	.1	.1	.1	.1								Negative
Wall	1.2	.9	1.0	1.03	.9	.7	.7	.76	.27			Negative
Duct Heat	4.4	4.2	4.4	4.3	3.0	3.1	3.0	1.3		529 Pearl-01		Abate
Shelf	.3	0	.2	.16								Negative
Shelf Bracket	.3	.4	.3	.33								Negative
Ceiling Plaster	1.0	.5	.5	.66	.4	.3	.3	.33	.33			Negative
Baseboard	10.0	10.0	10.0	10.0								Abate
BR1/EDC	.1	.1	.1	.1								Negative
BR1/DJ	0	0	0	0								Negative
BR1/IDC	0	0	0	0								Negative

BR1/Wall Plaster 1.0 .4 .3 .56 .3 .3 .3 .26

Negative







ENVIRONMENTAL CONTROL TECHNOLOGIES  
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 529 Pearl Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm <sup>2</sup> )				S.E.L. (mg/cm <sup>2</sup> )				C.L.C. (mg/cm <sup>2</sup> )	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
BR1/Ceiling	0	0	0	0								Negative
BR2/EDC	0	.1	0	.03								Negative
BR2/DJ	0	0	0	0								Negative
BR2/IDC	0	.1	.1	.06								Negative
BR2/Wall	2.2	2.2	2.8	2.4								Abate
BR2/WC	10.0	10.0	10.0	10.0								Abate
BR2/W. Sill	10.0	10.0	10.0	10.0								Abate
BR2/W. Apron	10.0	10.0	10.0	10.0								Abate
BR2/BB	10.0	10.0	10.0	10.0								Abate
BR2/Ceiling	.4	.4	.3	.36								Negative
BR2/EDC Closet	10.0	10.0	10.0	10.0								Abate
BR2/DJ	9.4	9.4	9.3	9.36								Abate
BR2/Wall	1.2	.6	.4	.73	.5	.5	.4	.46	.27			Negative











