

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 11, 1993 Apartment # 1008 Stone Street Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Hallway/Wall	0	.1	.1	.06								Negative
12x12 Ceiling Tile	0	0	0	0								Negative
BB	0	.1	0	.03								Negative
Door/Metal	.5	.5	.5	.50	.3	.2	.3	.26	.24			Negative
IDC	.1	.1	.1	.10								Negative
DJ	.8	.9	.8	.83	.4	.4	.4	.40	.43			Negative
EDC	.8	.8	.6	.73	.5	.4	.4	.43	.30			Negative
* CM	.7	.5	.5	.56	.5	.5	.4	.46	.10			Negative
<u>Bedroom #1</u>												
Wall	0	0	0	0								Negative
BB	.2	.2	.1	.16								Negative
Ceiling	0	0	.1	.03								Negative
Door	Not Painted											Negative

DJ 0 0 0 0

Negative

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 11, 1993 Apartment # 1008 Stone Street Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
IDC	0	0	0	0								Negative
WC	.3	.3	.3	.30								Negative
WA	.1	.3	.2	.20								Negative
WS	1.1	1.1	1.2	1.13	.4	.4	.4	.40	.73			<i>NEGATIVE</i>
Window Pane	1.0	1.0	.9	.96	.4	.4	.4	.40	.56			<i>NEGATIVE</i>
<u>Bedroom #2</u>												
Wall	0	0	.1	.03								Negative
Ceiling	0	0	0	0								Negative
BB	0	.1	0	.03								Negative
WC	0	.1	0	.03								Negative
WA	0	.1	0	.03								Negative
WS	0	0	0	0								Negative
Door	Not Painted											

Aluminum Windows

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 11, 1993 Apartment # 1008 Stone Street Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Door	0	0	0	0								Negative
Floor	0	.1	0	.03								Negative
WS	10.0	10.0	10.0	10.0								Abate
WC	10.0	10.0	10.0	10.0								Abate
WA	10.0	10.0	10.0	10.0								Abate
WP	10.0	10.0	10.0	10.0								Abate
<u>Restroom</u>												
Wall	0	0	.1	.03								Negative
Ceiling	0	0	0	0								Negative
Door Casing	0	0	0	0								Negative
Door Jamb	0	0	0	0								Negative
EDC	0	0	0	0								Negative
WC	.9	.4	.6	.63	.4	.3	.3	.33	.30			Negative

