

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 12, 1993 Apartment # 623 Taylor Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
WA	.1	.1	.1	.10								Negative
D	.1	.2	.2	.16								Negative
IDC	.2	.2	.1	.16								Negative
EDC	.3	.1	.1	.16								Negative
DJ	.1	.1	.1	.10								Negative
<u>Restroom/W</u>	.4	.4	.4	.40								Negative
CE	.3	.3	.2	.26								Negative
WS	.3	.4	.3	.33								Negative
WC	.2	.1	.4	.23								Negative
D	.1	.1	.1	.10								Negative
IDC	.2	.2	.2	.20								Negative
EDC	.1	.2	.3	.20								Negative
DJ	.2	.2	.4	.26								Negative

Tub Casing

.1 .3 .3 .23

Negative

