

ENVIRONMENTAL CONTROL TECHNOLOGIES  
LBP XK-3 SAMPLE SHEET

Date/Time: March 10, 1993 Apartment # 1311 Wamajo Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm <sup>2</sup> )				S.E.L. (mg/cm <sup>2</sup> )				C.L.C. (mg/cm <sup>2</sup> )	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
LR/W	Paneling											
LR/CE	.2	.4	.4	.33								Negative
LR/MD	1.0	.9	.7	.87	.4	.4	.5	.43	.44			Negative
LR/DJ	0	.1	.1	.06								Negative
LR/IDC	.1	.1	.1	.10								Negative
LR/WC	.1	0	.1	.06								Negative
Kit/W	0	.1	0	.03								Negative
Kit/CE	0	0	0	0								Negative
Kit/WC	.1	.2	.1	.13								Negative
Kit/D	.2	.2	.5	.30								Negative
Kit/IDC	.3	.3	.3	.30								Negative
Kit/DJ	.1	.2	.1	.13								Negative

Aluminum over EDC

ENVIRONMENTAL CONTROL TECHNOLOGIES  
LBP XK-3 SAMPLE SHEET

Date/Time: March 10, 1993 Apartment # 1311 Wamajo Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm <sup>2</sup> )				S.E.L. (mg/cm <sup>2</sup> )				C.L.C. (mg/cm <sup>2</sup> )	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
UR/W	0	0	0	0								Negative
UR/CE	.1	.1	0	.06								Negative
<u>Hallway</u>												
W	.1	.1	0	.06								Negative
CE	.1	.1	.1	.10								Negative
AA	.2	.1	0	.10								Negative
AC	0	0	.2	.06								Negative
MS	.6	.4	.4	.36								Negative
<u>Hallway Closet</u>												
W	.2	.1	.1	.13								Negative
CE	.1	.1	.1	.10								Negative
MD	.7	.6	.6	.63	.5	.5	.5	.50	.13			Negative
MS	.5	.5	.6	.53	.4	.5	.5	.46	.07			Negative



ENVIRONMENTAL CONTROL TECHNOLOGIES  
LBP XK-3 SAMPLE SHEET

Date/Time: March 10, 1993 Apartment # 1311 Wamajo Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm <sup>2</sup> )				S.E.L. (mg/cm <sup>2</sup> )				C.L.C. (mg/cm <sup>2</sup> )	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
DJ	.2	.1	0	.10								Negative
EDC	.1	.1	.1	.10								Negative
MD	.6	.5	.5	.53	.4	.4	.5	.43	.10			Negative
MS	.6	.6	.7	.63	.5	.5	.5	.50	.13			Negative
<u>Bedroom #2</u>												
W (white)	0	0	0	0								Negative
W (tan)	0	0	0	0								Negative
CE	0	0	0	0								Negative
WC	.2	.1	.1	.16								Negative
D	.2	.2	.2	.20								Negative
IDC	.1	.1	0	.06								Negative
DJ	.1	.1	.1	.10								Negative
IDC	.2	.1	0	.10								Negative

MS                      .7   .6   .6   .63   .4   .5   .4   .43                      .20                      Negative

