

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: February 17, 1993 Apartment # 514 E. Washington Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Closet Ceiling	.1	.1	.1	.1								Negative
Stair Casing	10.0	10.0	10.0	10.0								Abate
Stair Jamb	10.0	10.0	10.0	10.0								Abate
Stair Wall	.3	.3	.2	.26								Negative
Board in Stairwell	10.0	10.0	10.0	10.0								Abate
Stair Stringer	10.0	10.0	10.0	10.0								Abate
HW/Ceiling	0	0	0	0								Negative
BR3/Wall	.2	.2	.2	.2								Negative
BR3/BB	10.0	10.0	10.0	10.0								Abate
BR3/W. Sill	10.0	10.0	10.0	10.0								Abate
BR3/WC	10.0	10.0	10.0	10.0								Abate
BR3/Crown Mold.	.2	.2	.1	.16								Negative
BR3/Closet Wall	0	0	0	0								Negative

Stair covered with carpet/Wall covered with panel

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 9, 1993 Apartment # 514 E. Washington Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
<u>Exterior</u>												
Brick Walls	.4	.4	.5	.43								Negative
<u>Garage</u>												
Garage Door	0	0	0	0								Negative
Garage DJ	0	0	0	0								Negative
Garage DC	0	0	0	0								Negative
Siding	0	0	0	0								Negative
Metal Door	.5	.5	.4	.46								Negative
EDC	0	0	0	0								Negative
DJ	0	0	0	0								Negative

Windows Aluminum Covered, Soffitts Fascia Aluminum

ENVIRONMENTAL CONTROL TECHNOLOGIES
LBP XK-3 SAMPLE SHEET

Date/Time: March 9, 1993 Apartment # 514 E. Washington Project: Area 8 Site: Erie Metro. H.A.

Sample Number	Reading (mg/cm ²)				S.E.L. (mg/cm ²)				C.L.C. (mg/cm ²)	Conformation Test		Result Neg./Abate
	1	2	3	Avg	1	2	3	Avg		No.	Result	
Rear Porch Ce.	.4	.5	.5	.46								Negative
Rear Porch Sup.	4.9	4.8	4.5	4.73								Abate
Ext. Wind. Panes	3.9	3.6	3.7	3.73								Abate
Ext. Door	.2	.4	.4	.33								Negative

Vinyl Siding on Window/Side